



**AUTOMATION & PROCESS TECHNOLOGIES**

**Engineering**

1080 N. Crooks Road, Clawson, MI 48017-1097

Telephone: 248-435-0700 Fax: 248-435-0007

www.ametek.com www.ametekapt.com



April 16, 2013

**SUBJECT: 2000, 1980 and 1986XP Series Hazardous Area Enclosure Ratings**

The appropriately designated AMETEK APT 2000 series, 1980 series and 1986XP series hazardous area enclosures are rated as follows:

- NEMA 7, Class I, Division 1 & 2, Group D
- NEMA 9, Class II, Division 1 & 2, Group E,F,G

These enclosures are designed, manufactured and or altered to our interpretation of the following Underwriters Laboratory (UL) standards and have not been submitted for 3<sup>rd</sup> party approvals:

- UL 1203 Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations (Second Edition, July 27, 1994)
- UL 698 Industrial Control Equipment for Use in Hazardous (Classified) Locations (Twelfth Edition, June 22, 1995)

Glenn S. Loding  
Engineering Manager